

# Zone Report

Report Date: 29/01/2019

INTR000101 IR Fast Integrity

Zone No	Module No	Description
1	4865	Zone 1
8	4865	Zone 8
9	4865	Cabinet tamper
10	4865	AC fail
11	4865	Low battery
12	4865	LAN fuse
13	4865	Detector fuse
14	4865	Low Voltage on LAN+ or DET+
15	4865	Power supply fail
16	4865	Battery test
17	4865	Unibus
18	4865	Download Problem
19	4865	Spare1
20	4865	Lan Comms
21	4865	Door #1 Reed
22	4865	Door #2 Reed
23	4865	Door #3 Reed
24	4865	Door #4 Reed
25	4865	Door #5 Reed
26	4865	Door #6 Reed
27	4865	Door #7 Reed
28	4865	Door #8 Reed
29	4865	Door #1 Tongue
30	4865	Door #2 Tongue
31	4865	Door #3 Tongue
32	4865	Door #4 Tongue
33	4865	Door #5 Tongue
34	4865	Door #6 Tongue
35	4865	Door #7 Tongue
36	4865	Door #8 Tongue
37	4865	Door #1 Tamper
38	4865	Door #2 Tamper
39	4865	Door #3 Tamper
40	4865	Door #4 Tamper
41	4865	Door #5 Tamper

42	4865 Door #6 Tamper
43	4865 Door #7 Tamper
44	4865 Door #8 Tamper
45	4865 Door #1 Forced
46	4865 Door #2 Forced
47	4865 Door #3 Forced
48	4865 Door #4 Forced
49	4865 Door #5 Forced
50	4865 Door #6 Forced
51	4865 Door #7 Forced
52	4865 Door #8 Forced
53	4865 Door #1 DOTL
54	4865 Door #2 DOTL
55	4865 Door #3 DOTL
56	4865 Door #4 DOTL
57	4865 Door #5 DOTL
58	4865 Door #6 DOTL
59	4865 Door #7 DOTL
60	4865 Door #8 DOTL
61	4865 Rdr #1 Invalid
62	4865 Rdr #2 Invalid
63	4865 Rdr #3 Invalid
64	4865 Rdr #4 Invalid
65	4865 Rdr #5 Invalid
66	4865 Rdr #6 Invalid
67	4865 Rdr #7 Invalid
68	4865 Rdr #8 Invalid
69	4865 Rdr #9 Invalid
70	4865 Rdr #10 Invalid
71	4865 Rdr #11 Invalid
72	4865 Rdr #12 Invalid
73	4865 Rdr #13 Invalid
74	4865 Rdr #14 Invalid
75	4865 Rdr #15 Invalid
76	4865 Rdr #16 Invalid
77	4865 Rdr #1 Duress
78	4865 Rdr #2 Duress
79	4865 Rdr #3 Duress
80	4865 Rdr #4 Duress
81	4865 Rdr #5 Duress
82	4865 Rdr #6 Duress
83	4865 Rdr #7 Duress
84	4865 Rdr #8 Duress
85	4865 Rdr #9 Duress
86	4865 Rdr #10 Duress
87	4865 Rdr #11 Duress
88	4865 Rdr #12 Duress

89	4865 Rdr #13 Duress
90	4865 Rdr #14 Duress
91	4865 Rdr #15 Duress
92	4865 Rdr #16 Duress
93	4865 Rdr #1 Tamper
94	4865 Rdr #2 Tamper
95	4865 Rdr #3 Tamper
96	4865 Rdr #4 Tamper
97	4865 Rdr #5 Tamper
98	4865 Rdr #6 Tamper
99	4865 Rdr #7 Tamper
100	4865 Rdr #8 Tamper
101	4865 Rdr #9 Tamper
102	4865 Rdr #10 Tamper
103	4865 Rdr #11 Tamper
104	4865 Rdr #12 Tamper
105	4865 Rdr #13 Tamper
106	4865 Rdr #14 Tamper
107	4865 Rdr #15 Tamper
108	4865 Rdr #16 Tamper
109	4865 AC fail (External Power Supply)
110	4865 Low battery (External Power Supply)
111	4865 LAN fuse (External Power Supply)
112	4865 Detector fuse (External Power Supply)
113	4865 Low Voltage on LAN+ or DET+
114	4865 Power supply fail (External Power Supply)
115	4865 Battery test (External Power Supply)
116	4865 Door #1 Rex
117	4865 Door #2 Rex
118	4865 Door #3 Rex
119	4865 Door #4 Rex
120	4865 Door #5 Rex
121	4865 Door #6 Rex
122	4865 Door #7 Rex
123	4865 Door #8 Rex
124	4865 Door #1 Ren
125	4865 Door #2 Ren
126	4865 Door #3 Ren
127	4865 Door #4 Ren
128	4865 Door #5 Ren
129	4865 Door #6 Ren
130	4865 Door #7 Ren
131	4865 Door #8 Ren

