

Type Report

Report Date: 13/01/2021

0016000101 Paradox CID Template

Type No	Description	Action Plan
110	Alarm	General Alarm
301	Main Power Loss	General Alarm
303	Memory Corrupted	System Alarm
305	Loop Reset	System Alarm
309	Replace Batteries	System Alarm
310	Earth Fault	System Alarm
311	Battery Low Voltage	System Alarm
313	User Reset	System Alarm
320	Output Fault	System Alarm
323	On board siren fault	System Alarm
333	Address at fault	System Alarm
350	Communication Trouble	System Alarm
351	Telephone Line Fault	System Alarm
373	On board zones fault	General Alarm
391	Dedicated fault input	System Alarm
520	User Silence	System Alarm
531	Device added	System Alarm
571	Input Bypass (Disable)	Zone Bypass
572	Output Bypass (Disable)	Zone Bypass
602	Periodic Test	Test Report
604	User system verification	General Alarm
607	User Walk Test	Zone Info, No Alarm
625	User Time adjust	System Alert
627	User Login	System Alarm
628	User Logout	System Alarm
910	Evacuation	General Alarm
911	Manual verification disabled	General Alarm
915	Alarm Verification Prealarm	Null Action Plan
916	Alarm verification disabled	General Alarm
917	Loop Invalid Configuration	Restoral, No Alarm
918	Loop Restored	Restoral, No Alarm
919	Loop Open	Restoral, No Alarm
920	Loop Overcurrent	Restoral, No Alarm
921	Display Unit Fault	Restoral, No Alarm
922	Display Unit Restore	Restoral, No Alarm
924	Contamination fault	Null Action Plan
925	Double Address fault	Null Action Plan

926	System Low Power	Restoral, No Alarm
934	Aux Power Fault	Restoral, No Alarm
940	Remote User Connected	Restoral, No Alarm
941	Remote User Disconnected	Restoral, No Alarm
942	Remote User Timeout	Restoral, No Alarm