

Type Report

Report Date: 22/08/2013

CHRN000101 Chiron IRIS Template

Type No	Description	Action Plan
100	Medical Emergency	High Priority Alarm
101	Pendant Emergency	High Priority Alarm
102	Deadman Emergency	High Priority Alarm
110	Fire Alarm	High Priority Alarm
111	Smoke Alarm	Medium Priority Alarm
112	Act Combustion	Medium Priority Alarm
113	Fire Water Flow	Medium Priority Alarm
114	Fire Heat	Medium Priority Alarm
115	Fire Pull Station	Medium Priority Alarm
116	Fire Duct	Medium Priority Alarm
117	Fire Flame	High Priority Alarm
118	Fire Near Flame	High Priority Alarm
120	Panic Alarm	High Priority Alarm
121	Duress Alarm	High Priority Alarm
122	Terminal Duress	High Priority Alarm
123	Audible	Medium Priority Alarm
124	Duress Access Grant	Medium Priority Alarm
125	Duress Egress Grant	Medium Priority Alarm
130	Burglary	Medium Priority Alarm
131	Burglary Perimeter	Medium Priority Alarm
132	Burglary Interior	Medium Priority Alarm
133	24 Hour	Medium Priority Alarm
134	Entry / Exit Burglary	Medium Priority Alarm
135	Day / Night Burglary	Medium Priority Alarm
136	Burglary Outdoor	Medium Priority Alarm
137	Tamper	System Alarm
138	Burglary Near Alarm	Medium Priority Alarm
139	Intrusion Verifier	Medium Priority Alarm
140	General Alarm	Medium Priority Alarm
141	Polling Loop Open	System Alarm
142	Polling Loop Short	System Alarm
143	LAN Communicator	System Alarm
144	Sensor Tamper	System Alarm

145	Expansion Module Tmp	System Alarm
146	Silent Burglary	Medium Priority Alarm
147	Sensor Superv Fail	System Alarm
150	24 Hour Aux	System Alarm
151	Gas Detected	Medium Priority Alarm
152	Refrigeration	Low Priority Alarm
153	Loss of heat	Low Priority Alarm
154	Water leakage	Low Priority Alarm
155	Foil break alarm	Low Priority Alarm
156	Day trouble alarm	Low Priority Alarm
157	Low gas level	Low Priority Alarm
158	High Temperature	Low Priority Alarm
159	Low temperature	Low Priority Alarm
161	Loss of air flow	Low Priority Alarm
162	Carbon Mono. Detect	Low Priority Alarm
163	Tank Level	Low Priority Alarm
200	Fire Supervisory	Low Priority Alarm
201	SPV - Water P. Low	Low Priority Alarm
202	SPV - Low C02	Low Priority Alarm
203	SPV - Gate Valve	Low Priority Alarm
204	SPV - Water LV Low	Low Priority Alarm
205	SPV - Pump Active	Low Priority Alarm
206	SPV Pump Fail	Low Priority Alarm
300	System Trouble	System Alarm
301	Ac Loss	System Alarm
302	Low System Battery	System Alarm
303	Bad Ram Checksum	System Alarm
304	Bad Rom Checksum	System Alarm
305	System Reset	System Alarm
306	Program Altered	System Alarm
307	Zone Self Test	System Alarm
308	System Shutdown	System Alarm
309	Battery Test Fail	System Alarm
310	Ground Fault	System Alarm
311	Batt. Missing/Dead	System Alarm
312	PWR Spply Ovcurrnt	System Alarm
313	Engineer Reset	System Alarm
314	Primary Power Supply Failure	System Alarm
316	System Tamper	System Alarm
320	Siren/Output Trouble	System Alarm
321	Bell/Siren 1 Trouble	System Alarm

322	Bell/Siren 2 Trouble	System Alarm
323	Alarm Relay	System Alarm
324	Relay Trouble	System Alarm
325	Reversing Trbl	System Alarm
326	Notif. Applnce Ckt#3	System Alarm
327	Notif. Applnce CKT#4	System Alarm
330	System Peripheral	System Alarm
331	Sys Polling open	System Alarm
332	Sys Polling Shut	System Alarm
333	Expansion Module Fai	System Alarm
334	Repeater Fail	System Alarm
335	Printer Out Of Paper	System Alarm
336	Local Printer Fail	System Alarm
337	Exp. Mod DC Loss	System Alarm
338	Exp. Mod Low Bat	System Alarm
339	Exp. Mod Reset	System Alarm
341	Exp. Mod Tamper	System Alarm
342	Trbl Poll LP Sht	System Alarm
343	Trbl Exp. Mod Trb	System Alarm
344	RF Recv jam detect	System Alarm
345	AES Encryption Trouble	System Alarm
350	Communications Fail	System Alarm
351	Phone Line Fault	System Alarm
352	Telco 2 Fault	System Alarm
353	Lr Radio Fault	System Alarm
354	Dialer Fault	System Alarm
355	Loss Radio Sprv	System Alarm
356	Loss Central Plg	System Alarm
357	Radio VSWR probm	System Alarm
370	Protect. LP Trbl	System Alarm
371	Protect. LP Open	System Alarm
372	Protect. LP shrt	System Alarm
373	Fire Trouble	Medium Priority Alarm
374	Exit ER by zone	System Alarm
375	Panic zone trbl	Medium Priority Alarm
376	Holdup Zone Trbl	Medium Priority Alarm
377	Swinger Trbl	Medium Priority Alarm
378	Cross Zone Trbl	Medium Priority Alarm
380	Sensor TR Sy/N Z	System Alarm
381	Supervsn loss RF	System Alarm
382	Sensor Trouble	System Alarm
383	Sensor Tamper	System Alarm

384	RF Tran Low Bat	System Alarm
385	Smoke Det. Hi Sen	System Alarm
386	Smoke Det. Lo Sen	System Alarm
387	Intrs Det. Hi Sen	System Alarm
388	Intrs Det. Lo Sen	System Alarm
389	Sensor Slf-Tst Fail	System Alarm
391	Sensor Watch Trbl	System Alarm
392	Drift Compens. Error	System Alarm
393	Maintenance Alert	System Alarm
400	Open	Opening (Unset), No Alarm
401	Open By	Opening (Unset), No Alarm
402	Group Open By	Opening (Unset), No Alarm
403	Open Auto	Opening (Unset), No Alarm
404	Late Closing	Closing (Set), No Alarm
405	Deferred O/C	System Alarm
406	Cancel by user	System Alarm
407	Remote Open	Opening (Unset), No Alarm
408	Quick Open	Opening (Unset), No Alarm
409	Keyswitch Open	Opening (Unset), No Alarm
410	Remote Program Alter	System Alarm
411	Call back Req.	System Alarm
412	Successful Access	System Alarm
413	Unsuccesful Access	System Alarm
414	System Shutdown	System Alarm
415	Dialer Shutdown	System Alarm
416	Successful Upload	System Alarm
420	Door Forced Ajar	System Alarm
421	Access Denied	System Alarm
422	Access RPT/user	System Alarm
423	Forced Access	System Alarm
424	Access Denied	System Alarm
425	Egress Granted	System Alarm
426	Access Door Propped	System Alarm
427	Accss Door Stat. Trb	System Alarm
428	Accss Exit Rqst Trb	System Alarm
430	Access PProgram Exit	System Alarm
431	Access Level Change	System Alarm
432	Accss Rly/Trgr Fail	System Alarm
433	Access Rte Shunt	System Alarm
434	Access Dsm Shunt	System Alarm
435	Second Person Access	Opening (Unset), No Alarm
436	Irregular Access	Opening (Unset), No Alarm

441	Op/CL-Stay mode	System Alarm
442	Keyswitch Armd Stay	System Alarm
450	Exception O/C	Low Priority Alarm
451	Early O/C	Low Priority Alarm
452	Late O/C	Low Priority Alarm
453	Fail to Open	Low Priority Alarm
454	Fail To Close	Low Priority Alarm
455	Auto-Arm Fail	System Alarm
456	Partial O/C	System Alarm
457	Exit ER by User	System Alarm
458	User on Premiss	System Alarm
459	Recent O/C	System Alarm
461	Wrong Code Entry	System Alarm
462	Legal Code Entry	System Alarm
463	RE-Arm After Alarm	System Alarm
464	Auto-Arm Time Extnd	System Alarm
465	Panic Alarm Reset	System Alarm
466	Srvce on/off Prmiss	System Alarm
500	System Disable	System Alarm
501	Access Reader Disable	System Alarm
502	System Disable	System Alarm
503	System Disable	System Alarm
504	System Disable	System Alarm
505	System Disable	System Alarm
506	System Disable	System Alarm
507	System Disable	System Alarm
508	System Disable	System Alarm
509	System Disable	System Alarm
510	System Disable	System Alarm
520	Sndr/Rly Disable	System Alarm
521	Bell 1 Disable	System Alarm
522	Bell 2 Disable	System Alarm
523	Alrm Rly Disable	System Alarm
524	Trbl Rly Disable	System Alarm
525	RVSG Rly Disable	System Alarm
526	Notif. ApplnCE CKT #3	System Alarm
527	Notif. ApplnCE CKT#4	System Alarm
530	Periphrl Disable	System Alarm
531	Module Added Periphrl Disable	System Alarm
532	Module Removed Periphrl Disable	System Alarm
533	Periphrl Disable	System Alarm

534	Periphrl Disable	System Alarm
535	Periphrl Disable	System Alarm
536	Periphrl Disable	System Alarm
537	Periphrl Disable	System Alarm
538	Periphrl Disable	System Alarm
539	Periphrl Disable	System Alarm
540	Periphrl Disable	System Alarm
551	Dialer Disable	System Alarm
552	Radio TX Disable	System Alarm
553	Remote Up/Dnw Disbl	System Alarm
570	Zone Bypass	Closing (Set), No Alarm
571	Fire Bypass	Opening (Unset), No Alarm
572	24 Hour Zone Bypass	Opening (Unset), No Alarm
573	Burglary Bypass	Opening (Unset), No Alarm
574	Group Bypass	Opening (Unset), No Alarm
575	Swinger Bypass	System Alarm
576	Access Zone Shunt	System Alarm
577	Access Pint Bypass	System Alarm
601	Manual Test	Zone Info, No Alarm
602	Periodic Test	Zone Info, No Alarm
603	Periodic RF XMN	System Alarm
604	Fire Test	Medium Priority Alarm
605	Status RPT Next	System Alarm
606	Listen in next	System Alarm
607	Walk Test Mode	Zone Info, No Alarm
608	Sys Trbl PResent	System Alarm
609	Video TX Active	System Alarm
611	Point Tested OK	System Alarm
612	Point not Tested	System Alarm
613	Intrsn ZE Wlk Tested	System Alarm
614	Fire ZN Walk Tested	System Alarm
615	Panic ZN Walk Tested	System Alarm
616	Service Request	System Alarm
621	Event Log Reset	System Alarm
622	Eventlg 50% Full	System Alarm
623	Eventlg 90% Full	System Alarm
624	Eventlg Ovrlow	System Alarm
625	Time-Date Reset	System Alarm
626	Time-Date Wrong	System Alarm
627	Progr Mode Entry	System Alarm
628	Progr Mode Exit	System Alarm
629	32HrR Evnt Log Mrkr	System Alarm

630	Schedule Changed	Low Priority Alarm
631	Exception Sched. Change	Low Priority Alarm
632	Accss Schd Chnge	Low Priority Alarm
641	Senior Wtch Trbl	System Alarm
642	Latchkey Sprvsn	System Alarm
651	Reserved Adempco	System Alarm
652	Reserved Adempco	System Alarm
653	Reserved Adempco	System Alarm
654	System Inactivity	System Alarm
688	Periodic test	Zone Info, No Alarm
689	Raid Alarm	High Priority Alarm
1000	Restore Zone	Restoral, No Alarm
1100	Restore Medical	Restoral, No Alarm
1101	Restore Pendant tran	Restoral, No Alarm
1102	Restore Fail To Rprt	Restoral, No Alarm
1110	Restore Fire Alarm	Restoral, No Alarm
1111	Restore Smoke Alarm	Restoral, No Alarm
1112	Restore Act Combusti	Restoral, No Alarm
1113	Restore Fire Water Flow	Restoral, No Alarm
1114	Restore Fire Heat	Restoral, No Alarm
1115	Fire Pull Station Restore	Restoral, No Alarm
1116	Restore Fire Duct	Restoral, No Alarm
1117	Restore Fire Flame	Restoral, No Alarm
1118	Restore Fire Near Flame	Restoral, No Alarm
1120	Panic restore	Restoral, No Alarm
1121	Restore Duress Alarm	Restoral, No Alarm
1122	Restore Terminal Duress	Restoral, No Alarm
1123	Restore Audible	Restoral, No Alarm
1124	Restore Duress Access Grant	Restoral, No Alarm
1125	Restore Duress Egress Grant	Restoral, No Alarm
1130	Restore Zone	Restoral, No Alarm
1131	Restore Burglary Perimeter	Restoral, No Alarm
1132	Restore Burglary Interior	Restoral, No Alarm
1133	Restore 24H	Restoral, No Alarm
1134	Restore Entry / Exit Burglary	Restoral, No Alarm
1135	Restore Day / Night Burglary	Restoral, No Alarm
1136	Restore Burglary Out	Restoral, No Alarm

1137	Restore Tamper	Restoral, No Alarm
1138	Restore Burglary Near Alarm	Restoral, No Alarm
1139	Restore Intrusion Verifier	Restoral, No Alarm
1140	Restore Zone	Restoral, No Alarm
1141	Restore Polling Loop Open	Restoral, No Alarm
1142	Restore Polling Loop Short	Restoral, No Alarm
1143	Restore LAN Communicator	Restoral, No Alarm
1144	Restore Sensor Tamp	Restoral, No Alarm
1145	Restore	Restoral, No Alarm
1146	Restore Silent Burglary	Restoral, No Alarm
1147	Restore Sensor Superv Fail	Restoral, No Alarm
1150	Restore 24 Hour Aux	Restoral, No Alarm
1151	Restore Gas Detected	Restoral, No Alarm
1152	Restore Refrigeration	Restoral, No Alarm
1153	Restore Loss of heat	Restoral, No Alarm
1154	Restore Water leakage	Restoral, No Alarm
1155	Restore Foil break alarm	Restoral, No Alarm
1156	Restore Day trouble alarm	Restoral, No Alarm
1157	Restore Low gas level	Restoral, No Alarm
1158	Restore High Temperature	Restoral, No Alarm
1159	Restore Low temperature	Restoral, No Alarm
1161	Restore Loss of air flow	Restoral, No Alarm
1162	Restore Carbon Mono. Detect	Restoral, No Alarm
1163	Restore Tank Level	Restoral, No Alarm
1200	Restore Fire Supervisory	Restoral, No Alarm
1201	Restore SPV - Water P. Low	Restoral, No Alarm
1202	Restore SPV - Low C02	Restoral, No Alarm
1203	Restore SPV - Gate Valve	Restoral, No Alarm
1204	Restore SPV - Water LV Low	Restoral, No Alarm
1205	Restore SPV - Pump Active	Restoral, No Alarm
1206	Restore SPV Pump Fail	Restoral, No Alarm

1300	Restore Sys Trouble	Restoral, No Alarm
1301	Restore Ac Fail	Restoral, No Alarm
1302	Restore Low Sys Batt	Restoral, No Alarm
1303	Restore Bad Ram Checksum	Restoral, No Alarm
1304	Restore Bad Rom Checksum	Restoral, No Alarm
1305	Restore System Reset	Restoral, No Alarm
1306	Restore Program Altered	Restoral, No Alarm
1307	Restore Zone Self Test	Restoral, No Alarm
1308	Restore System Shutdown	Restoral, No Alarm
1309	Restore Battery Test Fail	Restoral, No Alarm
1310	Restore Ground Fault	Restoral, No Alarm
1311	Restore Batt. Missing/Dead	Restoral, No Alarm
1312	Restore PWR Spply Ovcurrnt	Restoral, No Alarm
1313	Restore Engineer Reset	Restoral, No Alarm
1314	Restore Primary Power Supply Failure	Restoral, No Alarm
1316	Restore System Tamper	Restoral, No Alarm
1320	Restore Siren/Output Trouble	Restoral, No Alarm
1321	Restore Bell/Siren	Restoral, No Alarm
1322	Restore Bell/Siren 2 Trouble	Restoral, No Alarm
1323	Restore Alarm Relay	Restoral, No Alarm
1324	Restore Relay Trouble	Restoral, No Alarm
1325	Restore Reversing Trbl	Restoral, No Alarm
1326	Restore Notif. Applnce Ckt#3	Restoral, No Alarm
1327	Restore Notif. Applnce CKT#4	Restoral, No Alarm
1330	Restore System Peripheral	Restoral, No Alarm
1331	Restore Sys Polling open	Restoral, No Alarm
1332	Restore Sys Polling Shut	Restoral, No Alarm
1333	Restore Expansion Module Fai	Restoral, No Alarm
1334	Restore Repeater Fail	Restoral, No Alarm
1335	Restore Printer Out Of Paper	Restoral, No Alarm
1336	Restore Local Printer Fail	Restoral, No Alarm

1337	Restore Exp. Mod DC Loss	Restoral, No Alarm
1338	Restore Exp. Mod Low Bat	Restoral, No Alarm
1339	Restore Exp. Mod Reset	Restoral, No Alarm
1341	Restore Exp. Mod Tamper	Restoral, No Alarm
1342	Restore Trbl Poll LP Sht	Restoral, No Alarm
1343	Restore Trbl Exp. Mod Trb	Restoral, No Alarm
1344	Restore RF Recv jam detect	Restoral, No Alarm
1345	Restore AES Encryption Trouble	Restoral, No Alarm
1350	Restore Communications Fail	Restoral, No Alarm
1351	Restore Phone Line Fault	Restoral, No Alarm
1352	Restore Telco 2 Fault	Restoral, No Alarm
1353	Restore Lr Radio Fault	Restoral, No Alarm
1354	Restore Dialer Fault	Restoral, No Alarm
1355	Restore Loss Radio Sprv	Restoral, No Alarm
1356	Restore Loss Central Plg	Restoral, No Alarm
1357	Restore Radio VSWR probm	Restoral, No Alarm
1370	Restore Protect. LP Trbl	Restoral, No Alarm
1371	Restore Protect. LP Open	Restoral, No Alarm
1372	Restore Protect. LP shrt	Restoral, No Alarm
1373	Restore Fire Trouble	Restoral, No Alarm
1374	Restore Exit ER by zone	Restoral, No Alarm
1375	Restore Panic zone trbl	Restoral, No Alarm
1376	Restore Holdup Zone Trbl	Restoral, No Alarm
1377	Restore Swinger Trbl	Restoral, No Alarm
1378	Restore Cross Zone Trbl	Restoral, No Alarm
1380	Restore Sensor TR Sy/N Z	Restoral, No Alarm
1381	Restore Supervsn loss RF	Restoral, No Alarm
1382	Restore Sensor Trouble	Restoral, No Alarm
1383	Restore Sensor Tamp	Restoral, No Alarm
1384	Restore RF Tran Low Bat	Restoral, No Alarm
1385	Restore Smoke Det. Hi Sen	Restoral, No Alarm

1386	Restore Smoke Det. Lo Sen	Restoral, No Alarm
1387	Restore Intrs Det. Hi Sen	Restoral, No Alarm
1388	Restore Intrs Det. Lo Sen	Restoral, No Alarm
1389	Restore Sensor Slf-Tst Fail	Restoral, No Alarm
1391	Restore Sensor Watch Trbl	Restoral, No Alarm
1392	Restore Drift Compens. Error	Restoral, No Alarm
1393	Restore Maintenance Alert	Restoral, No Alarm
1400	Close By	Closing (Set), No Alarm
1401	Close By	Closing (Set), No Alarm
1402	Close By	Closing (Set), No Alarm
1403	Close Auto	Closing (Set), No Alarm
1404	Restore Late Closing	Restoral, No Alarm
1405	Restore Deferred O/C	Restoral, No Alarm
1406	Restore Cancel by user	Restoral, No Alarm
1407	Remote Close	Closing (Set), No Alarm
1408	Quick Close	Closing (Set), No Alarm
1409	Keyswitch Close	Closing (Set), No Alarm
1410	Restore Remote Program Alter	Restoral, No Alarm
1411	Restore Call back Req.	Restoral, No Alarm
1412	Restore Successful Access	Restoral, No Alarm
1413	Restore Unsuccesful Access	Restoral, No Alarm
1414	Restore System Shutdown	Restoral, No Alarm
1415	Restore Dialer Shutdown	Restoral, No Alarm
1416	Restore Successful Upload	Restoral, No Alarm
1420	Restore Door Forced Ajar	Restoral, No Alarm
1421	Restore Acess Denied	Restoral, No Alarm
1422	Restore Access RPT/user	Restoral, No Alarm
1423	Restore Forced Access	Restoral, No Alarm
1424	Restore Access Denied	Restoral, No Alarm
1425	Restore Egress Granted	Restoral, No Alarm
1426	Restore Access Door Propped	Restoral, No Alarm
1427	Restore Accss Door Stat. Trb	Restoral, No Alarm
1428	Restore Accss Exit Rqst Trb	Restoral, No Alarm
1430	Restore Access PProgram Exit	Restoral, No Alarm

1431	Restore Access Level Change	Restoral, No Alarm
1432	Restore Accss Rly/Trgr Fail	Restoral, No Alarm
1433	Restore Access Rte Shunt	Restoral, No Alarm
1434	Restore Access Dsm Shunt	Restoral, No Alarm
1435	Restore Second Person Access	Restoral, No Alarm
1436	Restore Irregular Access	Restoral, No Alarm
1441	Restore Op/CL-Stay mode	Restoral, No Alarm
1442	Restore Keyswitch Armd Stay	Restoral, No Alarm
1450	Restore Exception O/C	Restoral, No Alarm
1451	Restore Early O/C	Restoral, No Alarm
1452	Restore Late O/C	Restoral, No Alarm
1453	Restore Fail to Open	Restoral, No Alarm
1454	Restore Fail To Close	Restoral, No Alarm
1455	Restore Auto-Arm Fail	Restoral, No Alarm
1456	Restore Partial O/C	Restoral, No Alarm
1457	Restore Exit ER by User	Restoral, No Alarm
1458	Restore User on Premiss	Restoral, No Alarm
1459	Restore Recent O/C	Restoral, No Alarm
1461	Restore Wrong Code Entry	Restoral, No Alarm
1462	Restore Legal Code Entry	Restoral, No Alarm
1463	Restore RE-Arm After Alarm	Restoral, No Alarm
1464	Restore Auto-Arm Time Extnd	Restoral, No Alarm
1465	Restore Panic Alarm Reset	Restoral, No Alarm
1466	Restore Srvce on/off Prmiss	Restoral, No Alarm
1500	Restore System Disable	Restoral, No Alarm
1501	Restore Access Reader Disable	Restoral, No Alarm
1502	Restore System Disable	Restoral, No Alarm
1503	Restore System Disable	Restoral, No Alarm
1504	Restore System Disable	Restoral, No Alarm
1505	Restore System Disable	Restoral, No Alarm
1506	Restore System Disable	Restoral, No Alarm
1507	Restore System Disable	Restoral, No Alarm

1508	Restore System Disable	Restoral, No Alarm
1509	Restore System Disable	Restoral, No Alarm
1510	Restore System Disable	Restoral, No Alarm
1520	Restore Sndr/Rly Disable	Restoral, No Alarm
1521	Restore Bell 1 Disable	Restoral, No Alarm
1522	Restore Bell 2 Disable	Restoral, No Alarm
1523	Restore Alrm Rly Disable	Restoral, No Alarm
1524	Restore Trbl Rly Disable	Restoral, No Alarm
1525	Restore RVSG Rly Disable	Restoral, No Alarm
1526	Restore Notif. Applnce CKT #3	Restoral, No Alarm
1527	Restore Notif. Applnce CKT#4	Restoral, No Alarm
1530	Restore Periphrl Disable	Restoral, No Alarm
1531	Restore Module Added Periphrl Disable	Restoral, No Alarm
1532	Restore Module Removed Periphrl Disable	Restoral, No Alarm
1533	Restore Periphrl Disable	Restoral, No Alarm
1534	Restore Periphrl Disable	Restoral, No Alarm
1535	Restore Periphrl Disable	Restoral, No Alarm
1536	Restore Periphrl Disable	Restoral, No Alarm
1537	Restore Periphrl Disable	Restoral, No Alarm
1538	Restore Periphrl Disable	Restoral, No Alarm
1539	Restore Periphrl Disable	Restoral, No Alarm
1540	Restore Periphrl Disable	Restoral, No Alarm
1551	Restore Dialer Disable	Restoral, No Alarm
1552	Restore Radio TX Disable	Restoral, No Alarm
1553	Restore Remote Up/Dnw Disbl	Restoral, No Alarm
1570	Restore Zone Bypass	Restoral, No Alarm
1571	Restore Fire Bypass	Restoral, No Alarm
1572	Restore 24 Hour Zone Bypass	Restoral, No Alarm
1573	Restore Burglary Bypass	Restoral, No Alarm
1574	Restore Group Bypass	Restoral, No Alarm

1575	Restore Swinger Bypass	Restoral, No Alarm
1576	Restore Access Zone Shunt	Restoral, No Alarm
1577	Restore Access Pint Bypass	Restoral, No Alarm
1601	Restore Manual Test	Restoral, No Alarm
1602	Restore Periodic Test	Restoral, No Alarm
1603	Restore Periodic RF XMN	Restoral, No Alarm
1604	Restore Fire Test	Restoral, No Alarm
1605	Restore Status RPT Next	Restoral, No Alarm
1606	Restore Listen in next	Restoral, No Alarm
1607	Restore Walk Test Mode	Restoral, No Alarm
1608	Restore Sys Trbl PResent	Restoral, No Alarm
1609	Restore Video TX Active	Restoral, No Alarm
1611	Restore Point Tested OK	Restoral, No Alarm
1612	Restore Point not Tested	Restoral, No Alarm
1613	Restore Intrsln ZE Wlk Tested	Restoral, No Alarm
1614	Restore Fire ZN Walk Tested	Restoral, No Alarm
1615	Restore Panic ZN Walk Tested	Restoral, No Alarm
1616	Restore Service Request	Restoral, No Alarm
1621	Restore Event Log Reset	Restoral, No Alarm
1622	Restore Eventlg 50% Full	Restoral, No Alarm
1623	Restore Eventlg 90% Full	Restoral, No Alarm
1624	Restore Eventlg Ovrlow	Restoral, No Alarm
1625	Restore Time-Date Reset	Restoral, No Alarm
1626	Restore Time-Date Wrong	Restoral, No Alarm
1627	Restore Progr Mode Entry	Restoral, No Alarm
1628	Restore Progr Mode Exit	Restoral, No Alarm
1629	Restore 32HrR Evnt Log Mrkr	Restoral, No Alarm
1630	Restore Schedule Changed	Restoral, No Alarm
1631	Restore Exception Sched. Change	Restoral, No Alarm
1632	Restore Accss Schd Chnge	Restoral, No Alarm
1641	Restore Senior Wtch Trbl	Restoral, No Alarm

1642	Restore Latchkey Sprvn	Restoral, No Alarm
1651	Restore Reserved Adempco	Restoral, No Alarm
1652	Restore Reserved Adempco	Restoral, No Alarm
1653	Restore Reserved Adempco	Restoral, No Alarm
1654	Restore System Inactivity	Restoral, No Alarm
1688	Restore Periodic test	Restoral, No Alarm
1689	Restore Raid Alarm	Restoral, No Alarm
8398	AN - Analog Restoral	Restoral, No Alarm
8402	AR-AC Restoral	Restoral, No Alarm
8403	AS - Analog Service	System Alarm
8404	AT-AC trouble	System Alarm
8513	BA-Burglary alarm	Medium Priority Alarm
8514	BB-Burglary bypass	Low Priority Alarm
8515	BC-Burglary cancel	Low Priority Alarm
8516	BD - Swinger Trouble	System Alarm
8517	BE - Swinger Trbl Restore	Restoral, No Alarm
8520	BH-Burglary A. rest.	Restoral, No Alarm
8522	BJ-Burglary T. rest.	Restoral, No Alarm
8525	BM - Burg Alarm Cross Pnt	Low Priority Alarm
8530	BR-Burglary restoral	Restoral, No Alarm
8531	BS-Burglary supervisory.	Low Priority Alarm
8532	BT-Burglary trouble	Medium Priority Alarm
8533	BU-Burglary unbypass	Low Priority Alarm
8534	BV-Burglary Verified	Low Priority Alarm
8536	BX-Burglary test	Low Priority Alarm
8538	BZ - Missing Supervision	Low Priority Alarm
8641	CA-Automatic closing	System Alarm
8644	CD - Closing Delinquent	System Alarm
8645	CE-Closing extend	System Alarm
8646	CF-Forced closing	System Alarm
8647	CG-Close area	System Alarm
8649	CI-Fail to close	Low Priority Alarm
8650	CJ-Late close	Low Priority Alarm
8651	CK-Early close	Low Priority Alarm
8652	CL-Closing report	Closing (Set), No Alarm
8653	CM - Missing Al-Recnt Cls	System Alarm

8656	CP-Automatic closing	System Alarm
8658	CR-Recent closing	System Alarm
8659	CS-Closing switch	System Alarm
8660	CT-Late to open	Low Priority Alarm
8663	CW-Was force armed	Low Priority Alarm
8666	CZ-PPoint closing	System Alarm
8769	DA - Card Assigned	System Alarm
8770	DB - Card Deleted	System Alarm
8771	DC-Access closed	System Alarm
8772	DD-Access denied	System Alarm
8773	DE - Request To Enter	System Alarm
8774	DF-Door forced	Low Priority Alarm
8775	DG-Access granted	System Alarm
8776	DH - Door Left Open-Rstrl	Restoral, No Alarm
8778	DJ - Door Forced - Trouble	Low Priority Alarm
8779	DK-Access lockout	System Alarm
8780	DL - Door Left Open-Alarm	System Alarm
8781	DM - Door Left Open-Trbl	System Alarm
8782	DN - Door Left Open	System Alarm
8783	DO-Access open	System Alarm
8784	DP - Access Denied-Bad TM	System Alarm
8785	DQ - Access Denied-Un Arm	System Alarm
8786	DR-Door restoral	Restoral, No Alarm
8787	DS-Door station	System Alarm
8788	DT-access trouble	System Alarm
8789	DU-dealer ID	System Alarm
8790	DV - Access Denied-Un Ent	System Alarm
8791	DW - Access Denied -Intrlk	System Alarm
8792	DX - Request To Exit	System Alarm
8793	DX - Door Locked	System Alarm
8794	DZ - Access Closed State	System Alarm
8897	EA-Exit Alarm	System Alarm
8901	EE-Exit error	System Alarm
8914	ER-Expansion rest.	Restoral, No Alarm
8916	ET-Expansion trouble	System Alarm

8920	EX - Extrnl Device State	System Alarm
8922	EZ - Missing Alarm-Ext ER	System Alarm
9025	FA-Fire alarm	High Priority Alarm
9026	FB-Fire bypass	Low Priority Alarm
9027	FC - Fire Cancel	Low Priority Alarm
9032	FH-Fire Alarm restore	Restoral, No Alarm
9033	FI-Firetest begin	Low Priority Alarm
9034	FJ-Fire trouble restore	Restoral, No Alarm
9035	FK-Fire test end	Low Priority Alarm
9037	FM - Fire Alarm Cross Pnt	High Priority Alarm
9042	FR-Fire restoral	Restoral, No Alarm
9043	FS-Fire supervisory	Low Priority Alarm
9044	FT-Fire trouble	High Priority Alarm
9045	FU-Fire unbypass	Low Priority Alarm
9048	FX-Fire test	Low Priority Alarm
9049	FY-Missing fire Trouble	Medium Priority Alarm
9050	FZ - Missing Fire Sprv	Medium Priority Alarm
9153	GA-Gas alarm	High Priority Alarm
9154	GB-Gas bypass	Low Priority Alarm
9160	GH-Gas A. restore	Restoral, No Alarm
9162	GJ-Gas T. restore	Restoral, No Alarm
9170	GR-Gas restoral	Restoral, No Alarm
9171	GS-Gas supervisory	Low Priority Alarm
9172	GT-Gas trouble	Medium Priority Alarm
9173	GU-Gas unbypass	Low Priority Alarm
9176	GX-Gas test gas	Low Priority Alarm
9281	HA-Hold up alam	Medium Priority Alarm
9282	HB-Hold-up bypass	Low Priority Alarm
9288	HH-Hold-up a. rest.	Restoral, No Alarm
9290	HJ-Hold-up T. rest.	Restoral, No Alarm
9298	HR-Hold-up restoral	Restoral, No Alarm
9299	HS-Hold-up supervisory	Low Priority Alarm
9300	HT-Hold-up trouble	Medium Priority Alarm
9301	HU-Hold-up unbypass	Low Priority Alarm
9409	IA - Eqpmt Fail Condition	System Alarm
9426	IR - Eqpmt Fail Restore	Restoral, No Alarm
65000	Receiver in error has Restored	Restoral, No Alarm
65001	Client Late to close	Low Priority Alarm
65002	No signals received	System Alarm

65003	Receiver Failure	System Alarm
65005	Manual Paging Signal	Zone Info, No Alarm
65006	Pager/Email Failure	System Alarm
65007	Client Unset out of hours	Low Priority Alarm
65009	IRFast descript logged without details	System Alarm
65012	Caller ID logged	Zone Info, No Alarm
65020	Polling Restore	Restoral, No Alarm
65021	Polling Failure	System Alarm
65022	IRFast No description logged	System Alarm
65023	Sleeping Attend Reactivated	Zone Info, No Alarm
65024		Zone Info, No Alarm
65025		Zone Info, No Alarm
65026	Change of Logs	Zone Info, No Alarm
65027	Successful Send	Zone Info, No Alarm
65028	Alarm no restoral received	System Alarm
65029	Bad checksum in signal	System Alarm
65030	Comm port error	System Alarm
65031	Bad Caller ID	System Alarm
65032	Bad Unrecognised Data	System Alarm
65046	Start of listen in	Zone Info, No Alarm
65047	End of listen in	Zone Info, No Alarm
65050	Multi-knock	Zone Info, No Alarm
65051	Late to open	Low Priority Alarm
65052	Early to close	Low Priority Alarm
65053	Email error	System Alarm
65054	Poll signal	Zone Info, No Alarm
65055	Receiver error message	System Alarm
65056	Attend report	Zone Info, No Alarm
65057	Publishing failed	System Alarm
65058	Publishing Restored	Restoral, No Alarm
65059	Attend Report Complete	Zone Info, No Alarm
65061	Task dropped off network	System Alarm
65062	Task Restored	Restoral, No Alarm
65063	Slave dropped off network	System Alarm
65064	Slave Restored	Restoral, No Alarm
65065	Archive of current log was successful	Zone Info, No Alarm
65066	Archive of current log has failed	System Alarm
65067	Archive clean was successful	Zone Info, No Alarm
65068	Archive clean has failed	System Alarm
65069	WWW archive was successful	Zone Info, No Alarm
65070	WWW archive has failed	System Alarm
65071	Automatic Data Backup was successful	Zone Info, No Alarm
65072	Automatic Data Backup has failed	System Alarm
65087	Reminder	Zone Info, No Alarm

