

Type Report

Report Date: 9/08/2019

CHRN000101 Chiron IRIS Template

Type No	Description	Action Plan
314	Primary Power Supply Failure	System Alarm
316	System Tamper	System Alarm
345	AES Encryption Trouble	System Alarm
435	Second Person Access	Opening (Unset), No Alarm
436	Irregular Access	Opening (Unset), No Alarm
654	System Inactivity	System Alarm
1111	Restore Smoke Alarm	Restoral, No Alarm
1113	Restore Fire Water Flow	Restoral, No Alarm
1114	Restore Fire Heat	Restoral, No Alarm
1116	Restore Fire Duct	Restoral, No Alarm
1117	Restore Fire Flame	Restoral, No Alarm
1118	Restore Fire Near Flame	Restoral, No Alarm
1121	Restore Duress Alarm	Restoral, No Alarm
1122	Restore Terminal Duress	Restoral, No Alarm
1123	Restore Audible	Restoral, No Alarm
1124	Restore Duress Access Grant	Restoral, No Alarm
1125	Restore Duress Egress Grant	Restoral, No Alarm
1131	Restore Burglary Perimeter	Restoral, No Alarm
1132	Restore Burglary Interior	Restoral, No Alarm
1134	Restore Entry / Exit Burglary	Restoral, No Alarm
1135	Restore Day / Night Burglary	Restoral, No Alarm
1138	Restore Burglary Near Alarm	Restoral, No Alarm
1139	Restore Intrusion Verifier	Restoral, No Alarm
1141	Restore Polling Loop Open	Restoral, No Alarm
1142	Restore Polling Loop Short	Restoral, No Alarm
1143	Restore LAN Communicator	Restoral, No Alarm
1146	Restore Silent Burglary	Restoral, No Alarm
1147	Restore Sensor Superv Fail	Restoral, No Alarm

1150	Restore 24 Hour Aux	Restoral, No Alarm
1151	Restore Gas Detected	Restoral, No Alarm
1152	Restore Refrigeration	Restoral, No Alarm
1153	Restore Loss of heat	Restoral, No Alarm
1154	Restore Water leakage	Restoral, No Alarm
1155	Restore Foil break alarm	Restoral, No Alarm
1156	Restore Day trouble alarm	Restoral, No Alarm
1157	Restore Low gas level	Restoral, No Alarm
1158	Restore High Temperature	Restoral, No Alarm
1159	Restore Low temperature	Restoral, No Alarm
1161	Restore Loss of air flow	Restoral, No Alarm
1162	Restore Carbon Mono. Detect	Restoral, No Alarm
1163	Restore Tank Level	Restoral, No Alarm
1200	Restore Fire Supervisory	Restoral, No Alarm
1201	Restore SPV - Water P. Low	Restoral, No Alarm
1202	Restore SPV - Low C02	Restoral, No Alarm
1203	Restore SPV - Gate Valve	Restoral, No Alarm
1204	Restore SPV - Water LV Low	Restoral, No Alarm
1205	Restore SPV - Pump Active	Restoral, No Alarm
1206	Restore SPV Pump Fail	Restoral, No Alarm
1303	Restore Bad Ram Checksum	Restoral, No Alarm
1304	Restore Bad Rom Checksum	Restoral, No Alarm
1305	Restore System Reset	Restoral, No Alarm
1306	Restore Program Altered	Restoral, No Alarm
1307	Restore Zone Self Test	Restoral, No Alarm
1308	Restore System Shutdown	Restoral, No Alarm
1309	Restore Battery Test Fail	Restoral, No Alarm
1310	Restore Ground Fault	Restoral, No Alarm
1311	Restore Batt. Missing/Dead	Restoral, No Alarm
1312	Restore PWR Sply Ovrcurrnt	Restoral, No Alarm
1313	Restore Engineer Reset	Restoral, No Alarm

1314	Restore Primary Power Supply Failure	Restoral, No Alarm
1316	Restore System Tamper	Restoral, No Alarm
1320	Restore Siren/Output Trouble	Restoral, No Alarm
1322	Restore Bell/Siren 2 Trouble	Restoral, No Alarm
1323	Restore Alarm Relay	Restoral, No Alarm
1324	Restore Relay Trouble	Restoral, No Alarm
1325	Restore Reversing Trbl	Restoral, No Alarm
1326	Restore Notif. Applnce Ckt#3	Restoral, No Alarm
1327	Restore Notif. Applnce CKT#4	Restoral, No Alarm
1330	Restore System Peripheral	Restoral, No Alarm
1331	Restore Sys Polling open	Restoral, No Alarm
1332	Restore Sys Polling Shut	Restoral, No Alarm
1333	Restore Expansion Module Fai	Restoral, No Alarm
1334	Restore Repeater Fail	Restoral, No Alarm
1335	Restore Printer Out Of Paper	Restoral, No Alarm
1336	Restore Local Printer Fail	Restoral, No Alarm
1337	Restore Exp. Mod DC Loss	Restoral, No Alarm
1338	Restore Exp. Mod Low Bat	Restoral, No Alarm
1339	Restore Exp. Mod Reset	Restoral, No Alarm
1341	Restore Exp. Mod Tamper	Restoral, No Alarm
1342	Restore Trbl Poll LP Sht	Restoral, No Alarm
1343	Restore Trbl Exp. Mod Trb	Restoral, No Alarm
1344	Restore RF Recv jam detect	Restoral, No Alarm
1345	Restore AES Encryption Trouble	Restoral, No Alarm
1350	Restore Communications Fail	Restoral, No Alarm
1352	Restore Telco 2 Fault	Restoral, No Alarm
1353	Restore Lr Radio Fault	Restoral, No Alarm
1354	Restore Dialer Fault	Restoral, No Alarm
1355	Restore Loss Radio Sprv	Restoral, No Alarm
1356	Restore Loss Central Plg	Restoral, No Alarm
1357	Restore Radio VSWR probm	Restoral, No Alarm
1370	Restore Protect. LP Trbl	Restoral, No Alarm

1371	Restore Protect. LP Open	Restoral, No Alarm
1372	Restore Protect. LP shrt	Restoral, No Alarm
1374	Restore Exit ER by zone	Restoral, No Alarm
1375	Restore Panic zone trbl	Restoral, No Alarm
1376	Restore Holdup Zone Trbl	Restoral, No Alarm
1377	Restore Swinger Trbl	Restoral, No Alarm
1378	Restore Cross Zone Trbl	Restoral, No Alarm
1380	Restore Sensor TR Sy/N Z	Restoral, No Alarm
1381	Restore Supervsn loss RF	Restoral, No Alarm
1382	Restore Sensor Trouble	Restoral, No Alarm
1384	Restore RF Tran Low Bat	Restoral, No Alarm
1385	Restore Smoke Det. Hi Sen	Restoral, No Alarm
1386	Restore Smoke Det. Lo Sen	Restoral, No Alarm
1387	Restore Intrs Det. Hi Sen	Restoral, No Alarm
1388	Restore Intrs Det. Lo Sen	Restoral, No Alarm
1389	Restore Sensor Slf-Tst Fail	Restoral, No Alarm
1391	Restore Sensor Watch Trbl	Restoral, No Alarm
1392	Restore Drift Compens. Error	Restoral, No Alarm
1393	Restore Maintenance Alert	Restoral, No Alarm
1405	Restore Deferred O/C	Restoral, No Alarm
1406	Restore Cancel by user	Restoral, No Alarm
1410	Restore Remote Program Alter	Restoral, No Alarm
1411	Restore Call back Req.	Restoral, No Alarm
1412	Restore Successful Access	Restoral, No Alarm
1413	Restore Unsuccesful Access	Restoral, No Alarm
1414	Restore System Shutdown	Restoral, No Alarm
1415	Restore Dialer Shutdown	Restoral, No Alarm
1416	Restore Successful Upload	Restoral, No Alarm
1420	Restore Door Forced Ajar	Restoral, No Alarm
1422	Restore Access RPT/user	Restoral, No Alarm
1423	Restore Forced Access	Restoral, No Alarm

1424	Restore Access Denied	Restoral, No Alarm
1425	Restore Egress Granted	Restoral, No Alarm
1426	Restore Access Door Propped	Restoral, No Alarm
1427	Restore Accss Door Stat. Trb	Restoral, No Alarm
1428	Restore Accss Exit Rqst Trb	Restoral, No Alarm
1430	Restore Access PProgram Exit	Restoral, No Alarm
1431	Restore Access Level Change	Restoral, No Alarm
1432	Restore Accss Rly/Trgr Fail	Restoral, No Alarm
1433	Restore Access Rte Shunt	Restoral, No Alarm
1434	Restore Access Dsm Shunt	Restoral, No Alarm
1435	Restore Second Person Access	Restoral, No Alarm
1436	Restore Irregular Access	Restoral, No Alarm
1441	Restore Op/CL-Stay mode	Restoral, No Alarm
1442	Restore Keyswitch Armd Stay	Restoral, No Alarm
1450	Restore Exception O/C	Restoral, No Alarm
1451	Restore Early O/C	Restoral, No Alarm
1452	Restore Late O/C	Restoral, No Alarm
1453	Restore Fail to Open	Restoral, No Alarm
1454	Restore Fail To Close	Restoral, No Alarm
1455	Restore Auto-Arm Fail	Restoral, No Alarm
1456	Restore Partial O/C	Restoral, No Alarm
1457	Restore Exit ER by User	Restoral, No Alarm
1458	Restore User on Premiss	Restoral, No Alarm
1459	Restore Recent O/C	Restoral, No Alarm
1461	Restore Wrong Code Entry	Restoral, No Alarm
1462	Restore Legal Code Entry	Restoral, No Alarm
1463	Restore RE-Arm After Alarm	Restoral, No Alarm
1464	Restore Auto-Arm Time Extnd	Restoral, No Alarm
1465	Restore Panic Alarm Reset	Restoral, No Alarm
1466	Restore Srvce on/off Prmiss	Restoral, No Alarm
1500	Restore System Disable	Restoral, No Alarm
1501	Restore Access Reader Disable	Restoral, No Alarm

1502	Restore System Disable	Restoral, No Alarm
1503	Restore System Disable	Restoral, No Alarm
1504	Restore System Disable	Restoral, No Alarm
1505	Restore System Disable	Restoral, No Alarm
1506	Restore System Disable	Restoral, No Alarm
1507	Restore System Disable	Restoral, No Alarm
1508	Restore System Disable	Restoral, No Alarm
1509	Restore System Disable	Restoral, No Alarm
1510	Restore System Disable	Restoral, No Alarm
1520	Restore Sndr/Rly Disable	Restoral, No Alarm
1521	Restore Bell 1 Disable	Restoral, No Alarm
1522	Restore Bell 2 Disable	Restoral, No Alarm
1523	Restore Alrm Rly Disable	Restoral, No Alarm
1524	Restore Trbl Rly Disable	Restoral, No Alarm
1525	Restore RVSG Rly Disable	Restoral, No Alarm
1526	Restore Notif. Applnce CKT #3	Restoral, No Alarm
1527	Restore Notif. Applnce CKT#4	Restoral, No Alarm
1530	Restore Periphrl Disable	Restoral, No Alarm
1531	Restore Module Added Periphrl Disable	Restoral, No Alarm
1532	Restore Module Removed Periphrl Disable	Restoral, No Alarm
1533	Restore Periphrl Disable	Restoral, No Alarm
1534	Restore Periphrl Disable	Restoral, No Alarm
1535	Restore Periphrl Disable	Restoral, No Alarm
1536	Restore Periphrl Disable	Restoral, No Alarm
1537	Restore Periphrl Disable	Restoral, No Alarm
1538	Restore Periphrl Disable	Restoral, No Alarm
1539	Restore Periphrl Disable	Restoral, No Alarm
1540	Restore Periphrl Disable	Restoral, No Alarm
1551	Restore Dialer Disable	Restoral, No Alarm
1552	Restore Radio TX Disable	Restoral, No Alarm

1553	Restore Remote Up/Dnw Disbl	Restoral, No Alarm
1571	Restore Fire Bypass	Restoral, No Alarm
1572	Restore 24 Hour Zone Bypass	Restoral, No Alarm
1573	Restore Burglary Bypass	Restoral, No Alarm
1574	Restore Group Bypass	Restoral, No Alarm
1575	Restore Swinger Bypass	Restoral, No Alarm
1576	Restore Access Zone Shunt	Restoral, No Alarm
1577	Restore Access Pint Bypass	Restoral, No Alarm
1601	Restore Manual Test	Restoral, No Alarm
1603	Restore Periodic RF XMN	Restoral, No Alarm
1605	Restore Status RPT Next	Restoral, No Alarm
1606	Restore Listen in next	Restoral, No Alarm
1607	Restore Walk Test Mode	Restoral, No Alarm
1608	Restore Sys Trbl PResent	Restoral, No Alarm
1609	Restore Video TX Active	Restoral, No Alarm
1611	Restore Point Tested OK	Restoral, No Alarm
1612	Restore Point not Tested	Restoral, No Alarm
1613	Restore Intrsn ZE Wlk Tested	Restoral, No Alarm
1614	Restore Fire ZN Walk Tested	Restoral, No Alarm
1615	Restore Panic ZN Walk Tested	Restoral, No Alarm
1616	Restore Service Request	Restoral, No Alarm
1621	Restore Event Log Reset	Restoral, No Alarm
1622	Restore Eventlg 50% Full	Restoral, No Alarm
1623	Restore Eventlg 90% Full	Restoral, No Alarm
1624	Restore Eventlg Ovrflow	Restoral, No Alarm
1625	Restore Time-Date Reset	Restoral, No Alarm
1626	Restore Time-Date Wrong	Restoral, No Alarm
1627	Restore Progr Mode Entry	Restoral, No Alarm
1628	Restore Progr Mode Exit	Restoral, No Alarm
1629	Restore 32HrR Evnt Log Mrkr	Restoral, No Alarm
1630	Restore Schedule Changed	Restoral, No Alarm

1631	Restore Exception Sched. Change	Restoral, No Alarm
1632	Restore Accss Schd Chnge	Restoral, No Alarm
1641	Restore Senior Wtch Trbl	Restoral, No Alarm
1642	Restore Latchkey Sprvsn	Restoral, No Alarm
1651	Restore Reserved Adempco	Restoral, No Alarm
1652	Restore Reserved Adempco	Restoral, No Alarm
1653	Restore Reserved Adempco	Restoral, No Alarm
1654	Restore System Inactivity	Restoral, No Alarm
1688	Restore Periodic test	Restoral, No Alarm
1689	Restore Raid Alarm	Restoral, No Alarm
8398	AN - Analog Restoral	Restoral, No Alarm
8402	AR-AC Restoral	Restoral, No Alarm
8403	AS - Analog Service	System Alarm
8404	AT-AC trouble	System Alarm
8513	BA-Burglary alarm	Intruder Alarm
8514	BB-Burglary bypass	System Alert
8515	BC-Burglary cancel	System Alert
8516	BD - Swinger Trouble	System Alarm
8517	BE - Swinger Trbl Restore	Restoral, No Alarm
8520	BH-Burglary A. rest.	Restoral, No Alarm
8522	BJ-Burglary T. rest.	Restoral, No Alarm
8525	BM - Burg Alarm Cross Pnt	System Alert
8530	BR-Burglary restoral	Restoral, No Alarm
8531	BS-Burglary supervisory.	System Alert
8532	BT-Burglary trouble	Intruder Alarm
8533	BU-Burglary unbypass	System Alert
8534	BV-Burglary Verified	System Alert
8536	BX-Burglary test	System Alert
8538	BZ - Missing Supervision	System Alert
8641	CA-Automatic closing	System Alarm
8644	CD - Closing Delinquent	System Alarm
8645	CE-Closing extend	System Alarm
8646	CF-Forced closing	System Alarm
8647	CG-Close area	System Alarm
8649	CI-Fail to close	System Alert
8650	CJ-Late close	System Alert

8651	CK-Early close	System Alert
8652	CL-Closing report	Closing (Set), No Alarm
8653	CM - Missing AI-Recnt Cls	System Alarm
8656	CP-Automatic closing	System Alarm
8658	CR-Recent closing	System Alarm
8659	CS-Closing switch	System Alarm
8660	CT-Late to open	System Alert
8663	CW-Was force armed	System Alert
8666	CZ-PPoint closing	System Alarm
8769	DA - Card Assigned	System Alarm
8770	DB - Card Deleted	System Alarm
8771	DC-Access closed	System Alarm
8772	DD-Access denied	System Alarm
8773	DE - Request To Enter	System Alarm
8774	DF-Door forced	System Alert
8775	DG-Access granted	System Alarm
8776	DH - Door Left Open-Rstrl	Restoral, No Alarm
8778	DJ - Door Forced - Trouble	System Alert
8779	DK-Access lockout	System Alarm
8780	DL - Door Left Open-Alarm	System Alarm
8781	DM - Door Left Open-Trbl	System Alarm
8782	DN - Door Left Open	System Alarm
8783	DO-Access open	System Alarm
8784	DP - Access Denied-Bad TM	System Alarm
8785	DQ - Access Denied-Un Arm	System Alarm
8786	DR-Door restoral	Restoral, No Alarm
8787	DS-Door station	System Alarm
8788	DT-access trouble	System Alarm
8789	DU-dealer ID	System Alarm
8790	DV - Access Denied-Un Ent	System Alarm
8791	DW - Access Denied -Intrlk	System Alarm
8792	DX - Request To Exit	System Alarm
8793	DX - Door Locked	System Alarm
8794	DZ - Access Closed State	System Alarm
8897	EA-Exit Alarm	System Alarm

8901	EE-Exit error	System Alarm
8914	ER-Expansion rest.	Restoral, No Alarm
8916	ET-Expansion trouble	System Alarm
8920	EX - Extrnl Device State	System Alarm
8922	EZ - Missing Alarm-Ext ER	System Alarm
9025	FA-Fire alarm	General Alarm
9026	FB-Fire bypass	System Alert
9027	FC - Fire Cancel	System Alert
9032	FH-Fire Alarm restore	Restoral, No Alarm
9033	FI-Firetest begin	System Alert
9034	FJ-Fire trouble restore	Restoral, No Alarm
9035	FK-Fire test end	System Alert
9037	FM - Fire Alarm Cross Pnt	General Alarm
9042	FR-Fire restoral	Restoral, No Alarm
9043	FS-Fire supervisory	System Alert
9044	FT-Fire trouble	General Alarm
9045	FU-Fire unbypass	System Alert
9048	FX-Fire test	System Alert
9049	FY-Missing fire Trouble	Intruder Alarm
9050	FZ - Missing Fire Sprv	Intruder Alarm
9153	GA-Gas alarm	General Alarm
9154	GB-Gas bypass	System Alert
9160	GH-Gas A. restore	Restoral, No Alarm
9162	GJ-Gas T. restore	Restoral, No Alarm
9170	GR-Gas restoral	Restoral, No Alarm
9171	GS-Gas supervisory	System Alert
9172	GT-Gas trouble	Intruder Alarm
9173	GU-Gas unbypass	System Alert
9176	GX-Gas test gas	System Alert
9281	HA-Hold up alam	Intruder Alarm
9282	HB-Hold-up bypass	System Alert
9288	HH-Hold-up a. rest.	Restoral, No Alarm
9290	HJ-Hold-up T. rest.	Restoral, No Alarm
9298	HR-Hold-up restoral	Restoral, No Alarm
9299	HS-Hold-up supervisory	System Alert
9300	HT-Hold-up trouble	Intruder Alarm
9301	HU-Hold-up unbypass	System Alert
9409	IA - Eqpmt Fail Condition	System Alarm
9426	IR - Eqpmt Fail Restore	Restoral, No Alarm

