

# Type Report

Report Date: 4/03/2020

CID5000101 Tecom Challenger CID V10 Large Template

Type No	Description	Action Plan
100	Medical Personal Emergency	Medical Alarm
101	Medical Pendant Transmitter	Medical Alarm
102	Dead Man's Alarm	Medical Alarm
110	Fire Alarm	Fire Alarm
111	Fire Smoke Detector	Fire Alarm
112	Fire Combustion	Fire Alarm
113	Fire Water Flow	Fire Alarm
114	Fire Heat Sensor	Fire Alarm
115	Fire Pull Station	Fire Alarm
116	Fire Duct Sensor	Fire Alarm
117	Fire Flame Sensor	Fire Alarm
118	Fire Near Alarm	Fire Alarm
120	Panic	Panic Alarm
121	Duress	Panic Alarm
122	Silent Panic	Panic Alarm
123	Audible Panic	Panic Alarm
130	Burglary	Intruder Alarm
131	Burglary Perimeter	Intruder Alarm
132	Burglary Interior	Intruder Alarm
133	Burglary 24 Hour	Intruder Alarm
134	Burglary Entry Exit	Intruder Alarm
135	Burglary Day/Night	Intruder Alarm
136	Burglary Outdoor	Intruder Alarm
137	Burglary Tamper	Intruder Alarm
138	Burglary Near Alarm	Intruder Alarm
140	General Alarm	General Alarm
142	General Alarm Exp Module Fail	General Alarm
143	Off-line	General Alarm
144	General Alarm Sensor Tamper	General Alarm
145	General Alarm Exp Module Tamper	General Alarm
150	Camera Film	General Alarm
151	24 Hour Gas Detected	General Alarm
152	24 Hour Refrigeration	System Alert
153	24 Hour Heating System	System Alert
154	24 Hour Water leakage	System Alert
155	24 Hour Foil Break	System Alert

156	24 Hour Day Zone	System Alert
157	24 Hour Low Gas level	System Alert
158	24 Hour High Temperature	System Alert
159	24 Hour Low Temperature	System Alert
160	24 Hour Air Flow	System Alert
200	Fire Supervisory	System Alert
201	Fire Supervisory Low Water Pressure	System Alert
203	Fire Supervisory Gate Valve	System Alert
204	Fire Supervisory Low Water Level	System Alert
205	Fire Supervisory Pump Activation	System Alert
206	Fire Supervisory Pump Failure	System Alert
300	Fuse Fail	System Alert
301	Mains Fail	System Alert
302	Low Battery	System Alert
303	Cipher Fail	System Alert
304	Dip Switched Changed	System Alert
305	CPU Restart	System Alert
309	Battery Test Fail	System Alarm
320	Siren Tamper	System Alarm
330	De-Polled	System Alarm
350	Communication Path Failure	System Alarm
351	Line Monitor Fail	System Alarm
381	Dectector Fail	System Alarm
383	Input In Fault	System Alarm
384	Detector Battery Low	System Alarm
393	Smoke Detector Dirty	System Alarm
402	Area Accessed	Opening (Unset), No Alarm
406	Cancel Code	Cancel By User
411	Service Requested	System Alert
416	Remote Login	System Alert
570	Input Isolated	Zone Bypass
602	Periodic Test	Test Report
608	Out Of Hours Access	System Alarm
701	Duress Battery Low	System Alarm
702	Duress Tamper	System Alarm
704	Ethernet Heartbeat Failed	System Alarm
706	Ethernet Hardware Init Failed	System Alarm
1100	Restore Medical Personal Emergency	Restoral, No Alarm
1101	Restore Medical Pendant Transmitter	Restoral, No Alarm
1102	Restore Medical Fail to Report In	Restoral, No Alarm
1110	Restore Fire Alarm	Restoral, No Alarm
1111	Restore Fire Smoke Detector	Restoral, No Alarm
1112	Restore Fire Combustion	Restoral, No Alarm
1113	Restore Fire Water Flow	Restoral, No Alarm

1114	Restore Fire Heat Sensor	Restoral, No Alarm
1115	Restore Fire Pull Station	Restoral, No Alarm
1116	Restore Fire Duct Sensor	Restoral, No Alarm
1117	Restore Fire Flame Sensor	Restoral, No Alarm
1118	Restore Fire Near Alarm	Restoral, No Alarm
1120	Restore Panic	Restoral, No Alarm
1122	Restore Silent Panic	Restoral, No Alarm
1123	Restore Audible Panic	Restoral, No Alarm
1130	Restore Burglary	Restoral, No Alarm
1131	Restore Burglary Perimeter	Restoral, No Alarm
1132	Restore Burglary Interior	Restoral, No Alarm
1133	Restore Burglary 24 Hour	Restoral, No Alarm
1134	Restore Burglary Entry Exit	Restoral, No Alarm
1135	Restore Burglary Day/Night	Restoral, No Alarm
1136	Restore Burglary Outdoor	Restoral, No Alarm
1137	Restore Burglary Tamper	Restoral, No Alarm
1138	Restore Burglary Near Alarm	Restoral, No Alarm
1140	Restore Holdup at Night	Restoral, No Alarm
1143	Restore General Alarm Exp Module Fail	Restoral, No Alarm
1144	Restore General Alarm Sensor Tamper	Restoral, No Alarm
1145	Restore General Alarm Exp Module Tamper	Restoral, No Alarm
1150	Restore 24 Hr Non-Burg	Restoral, No Alarm
1151	Restore 24 Hour Gas Detected	Restoral, No Alarm
1152	Restore 24 Hour Refrigeration	Restoral, No Alarm
1153	Restore 24 Hour Heating System	Restoral, No Alarm
1154	Restore 24 Hour Water Leakage	Restoral, No Alarm
1155	Restore 24 Hour Foil Break	Restoral, No Alarm
1156	Restore 24 Hour Day Zone	Restoral, No Alarm
1157	Restore 24 Hour Low Gas Level	Restoral, No Alarm
1158	Restore 24 Hour High Temperature	Restoral, No Alarm
1159	Restore 24 Hour Low Temperature	Restoral, No Alarm
1160	Restore 24 Hour Air Flow	Restoral, No Alarm
1200	Restore Fire Supervisory	Restoral, No Alarm
1201	Restore Fire Supervisory Low Water Press	Restoral, No Alarm
1203	Restore Fire Supervisory Gate Valve	Restoral, No Alarm
1204	Restore Fire Supervisory Low Water Level	Restoral, No Alarm
1205	Restore Fire Supervisory Pump Activation	Restoral, No Alarm
1206	Restore Fire Supervisory Pump Failure	Restoral, No Alarm
1300	Fuse Fail Restore	Restoral, No Alarm
1301	Mains Fail	Restoral, No Alarm
1302	Low Battery Restore	Restoral, No Alarm

1309	Battery Test Fail Restore	Restoral, No Alarm
1320	Siren Tamper Restore	Restoral, No Alarm
1330	De-Polled Restore	Restoral, No Alarm
1350	Communication Path Failure Restore	Restoral, No Alarm
1351	Line Monitor Fail Restore	Restoral, No Alarm
1381	Dectector Restore	Restoral, No Alarm
1383	Restore Input In Alarm	Restoral, No Alarm
1384	Detector Battery Low Restore	Restoral, No Alarm
1393	Smoke Detector Dirty Restore	Restoral, No Alarm
1402	Restore Area Secured	Closing (Set), No Alarm
1416	Remote Login Restore	Restoral, No Alarm
1570	Restore Input De-Isolated	Restoral, No Alarm
1608	Out Of Hours Access Restore	Restoral, No Alarm
1701	Duress Battery Low Restore	Restoral, No Alarm
1702	Duress Tamper Restore	Restoral, No Alarm
1704	Ethernet Heartbeat Restore	Restoral, No Alarm
1706	Ethernet Hardware Init Restore	Restoral, No Alarm